



GTEN 2019 Symposium

October 21-23, 2010 | Banff, Alberta

THE EFFECT OF AIR FILTRATION ON GAS TURBINE PERFORMANCE DEGRADATION – ISO 16890 AND ITS APPLICATION TO REAL ENGINE DATA

Ansaldo Energia Switzerland Ltd, Baden, Switzerland

Dr. Ulf Schirmeister / Frederick Mohr

Freudenberg Filtration Technologies SE & Co. KG, Weinheim, Germany

Thomas Schroth / Dr. Georg Hirsch / Patrick Weber

Presented by: Foad Goharanpour



Presented at the GTEN 2019 Symposium, Banff, Alberta, Canada - October 2019

The GTEN Committee shall not be responsible for statements or opinions advanced in technical papers or in symposium or meeting discussions.



Motivation


ISO 16890

New air filter test standard ISO 16890 is rating air filters based on separation efficiencies for dust fractions PM1, PM2.5 and PM10.

Publication of ASME GT2016-56292 "Gas turbine power degradation as a function of air filter classes" based on real engine data.


Can we find a correlation between the amount of dust in the combustion air after the filter system and the power loss of a gas turbine?

The software e.FFECT calculates clean air dust concentrations based on PM2.5 and PM10 and filter efficiencies





Better Filtration Reduces Fouling on Turbine Blades






GTEN 2019 Symposium


Higher Filtration Results in Less Degradation

[Source: ASME GT2016-56292]





Typical Particle Mass Distribution Density for Urban and Rural Environments [Used in ISO 16890]





Air Filter Rating according to ISO 16890

KEY DATA		eMaxx-98	eMaxx-E10	eMaxx-E11
Nominal volume flow rate	m ³ /h	4,250	4,250	3,400
Initial pressure drop	Pa	135	195	170
Class to ISO 16890		ISO ePM1 80%	ISO ePM1 > 95%	ISO ePM1 > 95%
Particulate matter efficiency				
ISO ePM1		83	97	98
ISO ePM2,5	%	87	98	99
ISO ePM10		95	99	> 99

Simplified explanation of PM fractions (PM = Particulate Matter):










- PM10 is the mass concentration of all airborne particles smaller than 10 µm
- PM2.5 is the mass concentration of all airborne particles smaller than 2.5 µm
- PM1 is the mass concentration of all airborne particles smaller than 1 µm

Dimension of PM_x is µg/m³



GTEN 2019 Symposium


Typical Mass Concentrations of PM_{2.5} and PM₁₀ Dust at Differently Characterized Locations

REGION	 RESIDENTIAL AREAS	 COUNTRY AREAS	 LIGHT-INDUSTRY AND URBAN AREAS	 HEAVY-INDUSTRY AREAS	 URBAN HIGHLY POLLUTED AREAS	 COASTAL REGIONS AND OFFSHORE	 DESERT AREAS	 ARCTIC AREAS	 TROPICAL AREAS
Ann. average PM ₁₀ [µg/m ³]	20–25	10–20	25–30	25–50	> 50	10–30	10–5,000	10–30	10–50
Ann. average PM _{2.5} [µg/m ³]	10–15	5–10	15–30	15–40	> 30	5–20	10–1,000	5–20	5–30


Sources for data:

- European Environment Agency (EEA) <http://www.eea.europa.eu/themes/air/interactive/pm10-interpolated-maps>
- World Health Organization (WHO) http://www.who.int/phe/health_topics/outdoorair/databases/cities/en
- Environmental Protection Agency (USA) <https://www.epa.gov/outdoor-air-quality-data/interactive-map-air-quality-monitors>
- Own measurements of dust fractions


Calculation for Multi-Stage Filtration Systems [Based on ISO 16890-1 Methodology]





34.4 $\mu\text{g}/\text{m}^3$



16.2 $\mu\text{g}/\text{m}^3$




5.6 $\mu\text{g}/\text{m}^3$





GTEN 2019 Symposium

e.FFECT Software for Calculating the Clean Gas Concentration by Using Ambient Air Data



Machine type: F-Class Turbine
Flow rate: 1,800,000 m³/h
Yearly operating hours: 6,000 h/year

Dust characteristics: Urban (according ISO 16890)
Input dust concentration: 25.0 µg/m³ PM₁₀

Input dust concentration: 25.0 µg/m³ PM₁₀

Total dust concentration: 34.4 µg/m³

Filter Stage 1:

480 T 60 1/1
3750 m³/h per filter




Filter Stage 2:

480 MX 95
3750 m³/h per filter



Filter Stage 3:

480 eMaxx E11
3750 m³/h per filter



SUMMARY OF SYSTEM PERFORMANCE

Total dust collected: 370.2 g

*Total efficiency: 99.6%

Total PM₁₀ efficiency: 99.8%


Total PM_{2.5} efficiency: 99.7%

Total PM₁ efficiency: 99.5%

Clean gas concentration: 0.15 µg/m³




Power Degradation as a Function of Dust Ingress Taken from Real Engine Data of Heavy Duty Gas Turbines





Power Degradation as a Function of Dust Ingress / Adjusted by Pressure Drop of Filters





Conclusions

- The survey of real gas turbine data showed a good correlation between the mass concentration of dust in the combustion air after the filtration system and the annual power degradation.
→ It is possible to quantify the benefits of enhanced filtration by calculating the resulting higher power output of a gas turbine.
- The amount of dust after the filter system can be calculated with the methodology of ISO 16890 based on ambient air data from an individual site by using the software e.FFECT.
- The power loss of a gas turbine is governed by the separation efficiency of the filter system while the pressure drop of the filters plays a subordinate role even for higher efficiency classes and multi-stage systems.