



GTEN 2019 Symposium

October 21-23, 2019 | Banff, Alberta

Day 1 – Training Session #2 Cogeneration, Combined-Cycle and Power Plant Basics

Jim Noordermeer, P.Eng.
Noord Power Consulting

Pascal Robichaud, P.Eng.
CEM Engineering

A brief introduction to the basics of cogeneration, combined-cycle and power plants, utilizing gas turbines and related equipment


Presented at the Gas Turbines Energy Network (GTEN) 2019 Symposium
Banff, Alberta, Canada - October 2019

The GTEN Committee shall not be responsible for statements or opinions advanced in technical papers or in symposium or meeting discussions.

SHP or SEPARATE HEAT-AND-POWER:

The “on-site heat/cooling production for industrial processes or space heating / cooling, and electricity purchase from the grid (large-scale power plants).”


Base Case



CHP / COGENERATION:

“The simultaneous production of two or more forms of useful energy (e.g. heat / cooling and electricity) from a single fuel source, usually on-site or nearby”




Cogeneration



MAJOR EQUIPMENT

Usually associated with Cogeneration / CHP cycles

- Gas turbine generator (GTG)
- Heat recovery steam generator (HRSG)
- Steam generators or boilers
- Steam turbine generator (STG)
- Reciprocating Gas, Dual-Fuel or Diesel Engine Generator



HEAT RECOVERY STEAM GENERATORS - HRSG

The high-temperature, high-flow exhaust of gas turbines can be utilized to make steam (or hot-water or to heat thermal oils) via a Heat Recovery Steam Generator (HRSG).

The HRSG steam produced can be used for:

- Directly for process, i.e. a combined-heat-and-power (**CHP**) or **cogeneration** process.
- Integration into a **combined-cycle** power plant, which makes electrical power via the gas turbine and a steam turbine.

There are many types and variations of HRSGs, including:

- **Single-Pressure HRSG** – making either saturated steam or superheated steam.
- **Dual-Pressure** – making steam at 2 pressure levels (high & lower pressures)
- **Triple-Pressure** – making steam at 3 different pressure levels (HP, IP & MP or LP)
- **Reheat HRSGs** – a multi-pressure HRSG where high pressure steam is re-introduced to the HRSG after it has partially expanded through a steam turbine, and is then re-heated towards the original high-pressure steam's temperature.
- **Firing** – HRSGs can be further classified by whether they are duct-fired or unfired. Gas turbines have sufficient oxygen in their exhausts to allow the introduction and combustion of additional fuel prior to the steam generation banks. Duct-firing increases steam production.
- **Fresh-Air Firing** – can be incorporated to allow the HRSG to behave like a boiler if the GTG is not operating.




Typical HRSG Configuration (Drum-Type)

The gas turbine exhaust gases flow through:

- **Superheater** section – adds sensible heat (temperature) to saturated steam.
- **Evaporator** section – produces only saturated steam (at constant temperature).
- **Economizer** section – adds sensible heat (temperature) to incoming feedwater.


The feedwater/steam flows in reverse to the turbine exhaust gases.



Once-Through Steam Generator (No Drums)

OTSGs were previously manufactured by Innovative Steam Technologies (IST) in Cambridge, Ontario. OTSGs can run “dry” meaning no water/steam in the tube banks.




An OTSG variation producing wet saturated steam is used for Enhanced Oil Recovery (EOR) in the Albertan Oil Sands regions.



STEAM TURBINES


Steam produced in the HRSG section(s) can be utilized in a steam turbine to produce additional electrical or mechanical power.

- **Backpressure** steam turbines make electricity & release steam to process.
- **Condensing** steam turbines make electricity only.
- **Extraction** steam turbines make electricity & release steam to process.
- Variations include extraction-condensing; admission-condensing; reheat; etc.




COGENERATION EXAMPLE

Base Case



COGENERATION EXAMPLE


Existing – Base Case



Cogeneration Case

COGENERATION EXAMPLE

Existing – Base Case




Cogeneration Case




COGENERATION EXAMPLE

Existing – Base Case




Cogeneration Case




COGENERATION EXAMPLE

Existing – Base Case




Cogeneration Case




COGENERATION EXAMPLE

Existing – Base Case




Cogeneration Case




COGENERATION EXAMPLE

Existing – Base Case




Cogeneration Case




COGENERATION EXAMPLE

Existing – Base Case




Cogeneration Case




COGENERATION EXAMPLE

Existing – Base Case



Cogeneration Case



Cycle Inputs:

Fuel: 829 mmbtu/hr


Cycle Outputs:

Steam: 200 kpph


Power: 97,000 kW

COGENERATION EXAMPLE

Existing – Base Case



Cogeneration Case



Cycle Inputs:

Fuel: 829 mmbtu/hr

Cycle Outputs:

Steam: 200 kpph
Power: 97,000 kW


Cogeneration or CHP Efficiency

$$\frac{[200,000 \times 1000] + [97,000 \times 3413]}{829,000,000}$$


= **64%** (or a Heat Rate of **5328** btu/kW.hr)

COGENERATION EXAMPLE

Existing – Base Case



Cogeneration Case




Total Cogeneration Fuel


829 mmbtu/hr

COGENERATION EXAMPLE

Existing – Base Case



Cogeneration Case




Total Cogeneration Fuel
Fuel-Chargeable-to-Steam (FCS)


829 mmbtu/hr
281 mmbtu/hr

COGENERATION EXAMPLE

Existing – Base Case



Cogeneration Case




Total Cogeneration Fuel
 Fuel-Chargeable-to-Steam (FCS)
 Fuel-Chargeable-to-Power (FCP)


829 mmbtu/hr
~~-281 mmbtu/hr~~
 548 mmbtu/hr

COGENERATION EXAMPLE

Existing – Base Case



Cogeneration Case



Cogeneration or CHP Heat Rate
5328 btu/kW.hr
64% Efficiency

FCP Heat Rate
5650 btu/kW.hr
60.4% Efficiency

3.5 MW Gas Turbine & HRSG London Health Sciences Centre, Ontario



4.5 MW Gas Turbine & HRSG Campbell's Soup – Toronto Ontario



55 MW Gas Turbine & HRSG – Whitby Cogeneration



World's 1st Rolls-Royce Trent DLE
IST dual-pressure OTSG (once-through steam generator)



GTAA Cogen – Toronto Airport



East Windsor Cogeneration Centre – Windsor
Before



After



Combined-Cycle Cogeneration – Lake Superior Power



West Windsor Power – Windsor



TransCanada Energy – Halton Hills Generating Station



Goreway Station Power – Toronto



COGENERATION, COMBINED-CYCLE & POWER PLANT BASICS[®]



Portlands Energy Centre – Toronto




COGENERATION, COMBINED-CYCLE & POWER PLANT BASICS[®]

ModernPowerSystems

DUNKIRK 2 x 400 MWe COMBINED CYCLE POWER PLANT Highly flexible generation with a combination of natural and steelworks gas

ALSTOM
ALSTOM
Power Turbines
Power Turbines
Power Turbines
11000 Avenue de la Vallée Wilson BP 35
91221 LA PALAISEAU-MONT 7E
France
Tel: (+33) 1 69 225 977
Fax: (+33) 1 69 225 620
www.power.alstom.com

d|6
d|6
381 Avenue du Président Wilson BP 35
91221 LA PALAISEAU-MONT 7E
France
Tel: (+33) 1 69 225 977
Fax: (+33) 1 69 225 620



Gas de France's 800 MWe Dunkirk 6 (D6K) plant in northern France adjacent to Alstom group's Sidra-Midrange steelworks can be regarded as France's first large combined cycle gas turbine (CCGT) project. Generating electricity flexibly using natural gas as well as steelworks (coke oven and blast furnace) gas, the plant is due to be fully operational in early 2005. It will supply electricity to the steelworks as well as selling electricity to the market through the RTE grid.

The basic concept is to improve the competitiveness of the Sidra facility while at the same time giving CCGT the opportunity for arbitrage between European gas and electricity markets.

The D6K plant will burn natural gas in two 115 MWe Alstom GT13E2 gas turbines, each coupled with a 345 MWe supplementary fired Mannheim-Lentjes heat recovery steam generator and a 240 MWe Alstom steam turbine.

The steelworks gases will be used for supplementary firing in the two vertical gas-firing HRSGs, the biggest such units in the world. Flexibility is a key feature of D6K, with two independent power trains, bypass stacks and fresh air fans in front of the boilers.

The power plant aims for an economically optimum mix of steelworks and natural gas.

All 400 MWe each train will achieve an efficiency of 50 per cent in combined cycle mode with the 345 MWe of supplementary firing. If steel gas is not available, the output of each train is reduced to 270 MWe (with efficiency remaining at 50 per cent). If natural gas is not used, each train can generate 150 MWe at 57 per cent efficiency while firing only steel mill gas in the HRSG.

Main technical data

Power plant
Type: Combined cyclic with supplementary firing
Integrated plant design point (C): 400
Gross electrical power (MW): 800
Gross efficiency (%): 50

Fuel
Natural gas (LHV): 35.5
Natural gas, blast furnace gas
Natural gas (HHV): 38.5
Coke oven gas (HHV): 38.5

Gas turbine
Number of units: 2
Supplier: ALSTOM
Type: GT13E2
Shut speed (rpm): 3000
Compression ratio: 14.6:1
Number of compressor stages: 21
Number of turbine stages: 5
Exhaust gas temperature (°C): 524
Inlet air mass flow (kg/s): 532
Low NO_x burner type: HV
NO_x emission (ppm): <25ppm

Steam turbine
Number of units: 2
Supplier: ALSTOM
Type: 3 pressure reheat and condensing
Configuration: Reaction type - double flow LP axial
Shut speed (rpm): 3000


Heat recovery steam generator
Number of units: 2
Supplier: Mannheim-Lentjes
Type: Vertical - 1 pressure reheat - supplementary firing - fresh air

HP steam
Main flow (kg/s): 146
Pressure (bar): 114
Temperature (°C): 565


IP steam - reheat
Main flow (kg/s): 147
Operating pressure (bar): 50
Temperature (°C): 565

Gas turbine generator
Number of units: 2
Supplier: ALSTOM
Type: Synchronous, air-cooled
Rated output (MVA): 108
Power factor: 0.85
Frequency (Hz): 50
Voltage (kV): 15.7


Steam turbine generator
Number of units: 2
Supplier: ALSTOM
Type: Synchronous, air-cooled
Rated output (MVA): 240
Power factor: 0.85
Frequency (Hz): 50
Voltage (kV): 18



- Key - site plan**
- A Gas turbine
 - B Control building
 - C Heat recovery steam generator
 - D Feedwater tank
 - E Reboiler pump building
 - F Industrial water recovery pit
 - G Unit electrical building
 - H Emergency diesel generator - common electrical building
 - I Water treatment plant
 - J Workshop & warehouse
 - K Air condenser station
 - L Reboiler pump building
 - M Fire fighting pump house
 - N Steam water basin
 - O Natural gas expansion station (GRF)
 - Q Steam turbine building



ALSTOM DKY23-2M18 steam turbine




ALSTOM GT13E2 gas turbine
Designed and illustrated by Mott MacDonald
18 King Alfred Way, Derby, DE22 2AG, UK



FUEL → ELECTRICITY → PROCESS HEAT


A. STEAM GENERATOR/STEAM TURBINE

THERMAL EFFICIENCY = 65 + 15 = 80%
 HEAT TO POWER RATIO = 65/15 = 4.3



B. GAS TURBINE/HRSG

THERMAL EFFICIENCY = 50 + 28 = 78%
 HEAT TO POWER RATIO = 50/28 = 1.8



GRYPHON
 INTERNATIONAL ENGINEERING SERVICES INC.

TOPPING CYCLES

ALL EFFICIENCIES ARE HHV

JAN. 2000


COGENERATION PRINCIPLES
 EXHIBIT 1

FUEL → PROCESS HEAT → ELECTRICITY

HRSG/STEAM TURBINE

THERMAL EFFICIENCY = 50 + 11 = 61%

HEAT TO POWER RATIO = 50/11 = 4.5



GRYPHON
INTERNATIONAL ENGINEERING SERVICES INC.

BOTTOMING CYCLE

ALL EFFICIENCIES ARE HHV


JAN. 2000

COGENERATION PRINCIPLES
EXHIBIT 2

FUEL → ELECTRICITY → PROCESS → ELECTRICITY

GAS TURBINE/HRSG/STEAM TURBINE

THERMAL EFFICIENCY = 28 + 15 + 14 = 57%
 HEAT TO POWER RATIO = 15/(28 + 14) = 0.36




GRYPHON
 INTERNATIONAL ENGINEERING SERVICES INC.

COMBINED CYCLE COGENERATION

ALL EFFICIENCIES ARE HHV

JAN. 2000

COGENERATION PRINCIPLES
 EXHIBIT 3




GRYPHON
INTERNATIONAL ENGINEERING SERVICES INC.

HEAT TO POWER RATIOS

JAN. 2000

COGENERATION PRINCIPLES
EXHIBIT 4

STEAM GENERATOR/BACKPRESSURE STEAM TURBINE



LOSSES AND AUXILIARY POWER = 3000 KW

$$\text{HHV THERMAL EFFICIENCY} = \frac{6000 + 60,000}{82,000} = 80\%$$

$$\text{HEAT/POWER RATIO} = \frac{60,000}{6000} = 10$$




GRYPHON
INTERNATIONAL ENGINEERING SERVICES INC.

TYPICAL HEAT BALANCE
ALUMINA PLANT APPLICATION

JAN. 2000

COGENERATION PRINCIPLES
EXHIBIT 5

STEAM GENERATOR/CONDENSING STEAM TURBINE



LOSSES AND AUXILIARY POWER = 5000 KW

$$\text{HHV THERMAL EFFICIENCY} = \frac{13,000 + 60,000}{110,000} = 66.4\%$$

$$\text{HEAT/POWER RATIO} = \frac{60,000}{13,000} = 4.6$$



GRYPHON INTERNATIONAL ENGINEERING SERVICES INC.

TYPICAL HEAT BALANCE PULP & PAPER APPLICATION

JAN. 2000


COGENERATION PRINCIPLES EXHIBIT 6

COMBINED CYCLE COGENERATION

STEAM HEAT TO PROCESS
 = 12,600 + 7,800
 = 20,400 KW THERMAL

NET ELECTRICAL OUTPUT
 = 39,800 + 15,000
 = 54,800 KW

LOSSES = 6,500 KW



HHV
 THERMAL = $\frac{54,800 + 20,400}{158,200} = 47.5\%$
 EFFICIENCY

HEAT/POWER = $\frac{20,400}{54,800} = 0.4$
 RATIO




GRYPHON
 INTERNATIONAL ENGINEERING SERVICES INC.

TYPICAL HEAT BALANCE COMBINED CYCLE APPLICATION

JAN. 2000

COGENERATION PRINCIPLES
 EXHIBIT 7

GAS TURBINE GENERATOR/HEAT RECOVERY STEAM GENERATOR



LOSSES AND AUXILIARY
POWER = 600 KW

HHV
THERMAL EFFICIENCY = $\frac{3520 + 15,660}{24,000} = 80\%$

HEAT/POWER RATIO = $\frac{15,660}{3520} = 4.4$



GRYPHON
INTERNATIONAL ENGINEERING SERVICES INC.

TYPICAL HEAT BALANCE
SMALL PROCESS PLANT APPLICATION

JAN. 2000

COGENERATION PRINCIPLES
EXHIBIT 8