



# GTEN 2021 Virtual Symposium

October 18<sup>th</sup> & 19<sup>th</sup>, 2021

## Carbon Capture and Industrial Gas Turbines

Dan Burnes, Rainer Kurz  
Solar Turbines Incorporated


The GTEN Committee shall not be responsible for statements or opinions advanced in technical papers or in symposium or meeting discussions.

# Increasing Carbon Pricing Initiatives - Tax / Trade / Credits

**Solar Turbines®**

A Caterpillar Company


Paris Agreement Price: \$40 - \$80/tCO<sub>2</sub>e in 2020  
(to achieve global avg temperature target of < 2°C)  
\$50 - \$100/tCO<sub>2</sub>e in 2030



Note: The British Columbia GGIRCA, Canada federal OBPS, Kazakhstan ETS, Nova Scotia CaT, Newfoundland and Labrador PSS, Saskatchewan OBPS, and Washington CAR are not shown in this graph as price information is not available for those initiatives. The carbon tax rate applied in Argentina, Finland, Ireland, Mexico and Norway varies with the fossil fuel type and use. The carbon tax rate applied in Denmark and Iceland varies with the GHG type. The graph shows the average carbon tax rate weighted by the amount of emissions covered at the different tax rates in those jurisdictions.

\*Source – World Bank Group, State and Trends of Carbon Pricing 2020

# CO<sub>2</sub> Emissions of Gas Turbine Products



# Carbon Capture Equipment

- Traditionally, carbon capture has been with the amine process
  - CO<sub>2</sub> absorbed into a liquid, then heated to drive off CO<sub>2</sub>
  - High capital cost of equipment a disadvantage with Solar engines, better with bigger systems
- Efforts mostly on mole sieve capture
  - Adsorption process, smaller and less expensive than the amine system, better with smaller systems
- In both cases:
  - The absorber / adsorption bed size/cost scales with the inverse square root of the purity based on constant velocity and dwell time
  - The amount of CO<sub>2</sub> that can be captured is linear with the concentration, or 7X greater at 21% CO<sub>2</sub> than 3% CO<sub>2</sub>




Figure 24 Amine Carbon Capture Process (from DOE/NETL)




Figure 26 Multi-Bed Adsorption (Mole Sieve) Capture Process





Figure 25 Normalized Absorber Diameter vs. CO<sub>2</sub> Inlet Purity

# Carbon Capture Economics

- Gas turbines have about 3% molar fraction of CO<sub>2</sub> concentration in the exhaust
- To make CC economical the concentration of CO<sub>2</sub> is essential
- Exhaust Gas Recirculation (EGR) is an enabler to increase CO<sub>2</sub> concentration in the exhaust of a gas turbine




\*Source – M.M. Faruque Hasan, Eric L. First, Fani Boukouvala, Christodoulos A. Floudasa, A multi-scale framework for CO<sub>2</sub> capture, utilization, and sequestration: CCUS and CCU, Journal of Computers and Chemical Engineering, May 2015



# Simulation of Overall Gas Turbine Engine System with Exhaust Gas Recirculation (EGR)

## Detailed Accounting

- Part Load Controls
  - DLE and conventional
- Thermal analysis
- Gas/liquid constituents
- Non-dimensional behavior
- EGR levels
- O<sub>2</sub> supplementation




# Considerations for EGR Optimization


- Recycling exhaust gas (high CO<sub>2</sub>, lower O<sub>2</sub>) into gas turbine inlet
- Effect of non-dimensional characterizations, especially the compressor
- Part load operation for different combustion systems DLE and conventional
- Minimize cost while maximizing performance and CO<sub>2</sub> capture
- Must cool exhaust...
  - Leverage waste heat to maximize utilization of fuel energy, consider bottoming cycles
  - Capture and use condensing water in the exhaust

# Bottoming Cycles - Reduce Carbon Intensity


## CHP – HRSG, WHRS



## sCO2 Bottoming Cycle



## Steam Generator




Utility steam turbines from 90 to 1,900 MW




Industrial steam turbines from 2 to 250 MW



Dresser-Rand steam turbines from <10 kW to 25 MW



## ORC (Organic Rankine Cycles)





# Parametric Analysis with EGR System Model

- Power improves with EGR
- Efficiency same or less
- Hot End Drive (HED) improves more than the Cold End Drive (CED)




Figure 8. HED EGR Parametric with 100°F inlet – Relativized Thermal Eff vs Power (CED in gray for comparison)




Figure 9. HED Ambient Temperature Lapse Rate with and without EGR – Relativized Thermal Eff vs Power




Figure 3. CED Ambient Temperature Lapse Rate with and without EGR – Relativized Thermal Eff vs Power

# Parametric Analysis with EGR System Model

- Minimum required  $O_2$  levels determined by combustion analysis
- $CO_2$  molar fraction levels and exhaust flow set by amount of EGR




Figure 4. CED EGR Parametric with 100°F inlet – Supplemental  $O_2$  vs  $O_2$  MF into the burner




Figure 6. CED EGR Parametric with 100°F inlet – Exhaust mass flow vs Exhaust  $CO_2$  MF






Figure 5. CED EGR Parametric with 100°F inlet – Exhaust  $CO_2$  vs  $O_2$  MF into the burner

# Parametric Analysis with EGR System Model

- Full Load Analysis Results – Power and Thermal Efficiency
- O<sub>2</sub> addition to set combustion inlet conditions at least ~15% O<sub>2</sub> MF




**Figure 2. Full Load @ Constant EGR Levels – Relativized Power vs Inlet Temperature**




**Figure 3. Full Load @ Constant EGR Levels – Thermal Efficiency vs Inlet Temperature**

# Parametric Analysis with EGR CED System Model

- Full Load Analysis Results – Required supplemental  $O_2$ ,  $CO_2$  in exhaust flow




**Figure 4. Full Load @ Constant EGR Levels – Added  $O_2$  at the GT Inlet vs Inlet Temperature**




**Figure 7. Full Load @ Constant EGR Levels – MF  $CO_2$  in Exhaust vs Inlet Temperature**



# Effect of EGR on Exhaust Gas Constituents and Inlet Gas Properties



**Figure 15. CED Exhaust Gas Constituents**



**Figure 16. CED Engine Inlet Gas Properties**



# Parametric Analysis with EGR System Model

- Compressor non-dimensional characteristics drive performance behavior
- Higher CO<sub>2</sub>, more mass flow through the engine

Flow




Figure 10. CED Compressor Characteristics –  $W_{eq}$  vs  $N_{ac}$

CED

Eff




Figure 12. CED Compressor Characteristics – Eff vs  $N_{ac}$

Flow




Figure 13. HED Compressor Characteristics –  $W_{eq}$  vs  $N_{ac}$

HED

Eff





Figure 14. HED Compressor Characteristics – Eff vs  $N_{ac}$

# Combustion Behavior with EGR System

## Chemical reactor network model of combustion system



- Analysis of emissions, behavior with reduced  $O_2$  (blow out), and noting laminar flame speed and change in equivalence ratio
- $O_2$  mole fraction in the range of 14% and 16% is suitable from the emissions and flame stability point of view
- There is a potential to reduce  $NO_x$  emissions using EGR running with reduced  $O_2$ . CO will still be negligible.




Figure 20. Ratio of predicted laminar flame speeds of the fuel-air mixtures to its value at no EGR condition




Figure 17. Ratio of actual equivalence ratio to equivalence ratio at no EGR for different level of  $O_2$  in the combustion air




Figure 19. Ratio of corrected (15%  $O_2$ , dry) actual  $NO_x$  to  $NO_x$  at no EGR




Figure 21. CO (15%  $O_2$ , ppm) emissions relative to its no EGR value at 100% fuel flow versus reduction in fuel in the fuel-air mixture at full-load condition

# Conclusions and Final Thoughts

- Eliminating CO<sub>2</sub> emissions from gas turbine engines is highly desirable due to environmental and especially economic consequences
- Study concludes it is feasible to operate single or two shaft industrial gas turbine engines with significant amount of EGR, though requiring supplemental O<sub>2</sub>
  - More O<sub>2</sub> addition is needed with higher EGR levels to sustain robust combustion
  - Gas turbines have about 3% molar fraction (MF) (4.7% mass fraction) of CO<sub>2</sub> concentration in the exhaust
  - For improved CC costs the target would be to increase the CO<sub>2</sub> concentration in the exhaust to at least 6% molar fraction
  - At 50% EGR, the gas turbine may not need supplemental O<sub>2</sub>

# Conclusions and Final Thoughts (cont)

- Power will increase substantially with higher levels of EGR
- EGR increases the CO<sub>2</sub> concentration in the exhaust and reduces the exhaust flow. The Gas Cleanup System (GCS), scales inversely with this increased concentration.
  - Reduces the size of the capture system
  - Reduces power required to operate the capture system
  - Reduces number of stages or number of trains of capture system skids